

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
<b>AGINCOURT (E)</b>	√		√		
<b>ALBERT CAMPBELL (E)</b>		X		X	Major barriers - Lack of access to lower level meeting room; steep ramp to main entrance; accessible washroom does not meet standards - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights; elevator Braille signage and audible floor call required - To be completed through Operating Budget, 2003.
<b>ALBION (W)</b>	√		√		
<b>ALDERWOOD (W)</b>	√		√		
<b>AMESBURY PARK (N)</b>	√		√		
<b>ANNETTE (S)</b>	√			X	Major barriers - Stairs to magazine area; lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>ARMOUR HEIGHTS (N)</b>	√		√		
<b>BARBARA FRUM (N)</b>	√		√		
<b>BAYVIEW (N)</b>	√		√		
<b>BEACHES (S)</b>	√			X	Major barrier - Lift to be replaced with elevator. Fire alarm strobe lights required. To be completed through Capital Program, 2003. Barrier free access to mezzanine levels is not feasible.
<b>BENDALE (E)</b>	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>BIBLIOGRAPHIC SERVICES (S)</b>	√		√		
<b>BLACK CREEK (N)</b>	√		√		
<b>BLOOR/GLADSTONE (S)</b>	√			X	Major barriers - Automatic doors required; lift to be replaced with elevator; accessible washroom does not meet standards - To be completed through Capital Program, 2005. Fire alarm strobe lights required - To be completed through Operating Budget, 2003.

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
<b>BRENTWOOD (W)</b>		X		X	Major barriers - Accessible ramp does not meet standards; elevator required; no accessible washroom - To be completed through Capital Program (beyond 2007).
<b>BRIDLEWOOD (E)</b>	✓		✓		
<b>BROOKBANKS (N)</b>	✓		✓		
<b>BURROWS HALL (E)</b>	✓		✓		
<b>CEDARBRAE (E)</b>	✓			X	Major barriers - Railing heights and accessible washroom do not meet standards; staff stairs to basement too steep - To be completed through Capital Program (beyond 2007).
<b>CENTENNIAL (N)</b>	✓		✓		
<b>CITY HALL (S)</b>	✓		✓		
<b>CLIFFCREST (E)</b>	✓			X	Major barrier - Accessible washroom does not meet standards - To be completed through Capital Program (beyond 2007).
<b>COLLEGE/SHAW (S)</b>	✓			X	Major barrier - Lift to be replaced with elevator for basement program room - To be completed through Capital Program (beyond 2007).
<b>DANFORTH/COXWELL (S)</b>	✓			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>DAVENPORT (S)</b>	✓			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>DAWES ROAD (E)</b>	✓		✓		
<b>DEER PARK (S)</b>	✓		✓		
<b>DON MILLS (N)</b>	✓			X	Elevator Braille signage required - To be completed through Operating Budget, 2003.
<b>DOWNSVIEW (N)</b>	✓			X	Elevator Braille signage required - To be completed through Operating Budget, 2003.
<b>DUFFERIN/ST. CLAIR (S)</b>	✓			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>EATONVILLE (W)</b>	✓		✓		
<b>EGLINTON SQUARE (E)</b>	✓		✓		

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
ELLESMORE OFFICES (E)		X		X	Major barriers - No accessible washroom; automatic door required - To be completed through Capital Program (beyond 2007).
ELMBROOK PARK (W)	√		√		
EVELYN GREGORY (W)		X		X	Major barrier - Accessible washroom does not meet standards - To be completed through Capital Program (beyond 2007).
FAIRVIEW (N)	√		√		
FLEMINGDON PARK (N)	√		√		
FOREST HILL (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
GERRARD/ASHDALE (S)	√			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
GOLDHAWK PARK (E)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
GUILDWOOD (E)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
HIGH PARK (S)	√			X	To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003. Barrier free access to mezzanine levels is not feasible.
HIGHLAND CREEK (E)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
HILLCREST (N)	√		√		
HUMBER BAY (W)	√		√		
HUMBER SUMMIT (N)	√			X	Elevator Braille signage required - To be completed through Operating Budget, 2003.
HUMBERWOOD (W)	√		√		

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
JANE DUNDAS (W)	√			X	Major barriers - No accessible washroom; some public areas inaccessible; elevator required - To be completed through Capital Program, 2006. Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
JANE SHEPPARD (N)	√		√		
JONES (S)	√			X	Major barrier - Automatic door required. To be completed through Capital Program, 2007. Fire alarm strobe lights - To be completed through Operating Budget, 2003.
KENNEDY/EGLINTON (E)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
LEASIDE (E)	√		√		
LILLIAN H. SMITH (S)	√		√		
LOCKE (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
LONG BRANCH (W)	√			X	Major barriers - Automatic doors required at main entrance; accessible washroom does not meet standards - To be completed through Capital Program, 2003.
MAIN STREET (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
MALVERN (E)	√		√		
MARIA A. SHCHUKA (W)	√		√		New building under construction; will be fully accessible.
MARYVALE (E)	√		√		
MCGREGOR PARK (E)	√			X	Major barrier - Accessible washroom does not meet standards. Fire alarm strobe lights required. To be completed through Capital Program, 2003.
MIMICO (W)		X		X	Major barriers - Railings too high - To be completed through Capital Program (beyond 2007). Barrier free access to mezzanine levels is not feasible.
MORNINGSIDE (E)	√		√		

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
<b>MOUNT DENNIS (W)</b>	√			X	Elevator Braille signage and audible floor call; accessible washroom sink and faucets required - To be completed through Operating Budget, 2003.
<b>MOUNT PLEASANT (S)</b>	√			X	Fire alarm strobe lights; elevator telephone and audible floor call required - To be completed through Operating Budget, 2003.
<b>NEW TORONTO (W)</b>	√			X	Fire alarm strobe lights and audible fire alarm required - To be completed through Operating Budget, 2003.
<b>NORTH YORK CENTRAL (N)</b>	√		√		
<b>NORTHERN DISTRICT (S)</b>	√			X	Fire alarm strobe lights; elevator telephone and audible floor call required - To be completed through Operating Budget, 2003.
<b>NORTHERN ELMS (W)</b>	√		√		
<b>OAKWOOD VILLAGE (W)</b>	√			X	Fire alarm strobe lights; elevator Braille signage and audible floor call required - To be completed through Operating Budget, 2003.
<b>PALMERSTON (S)</b>	√			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>PAPE/DANFORTH (S)</b>	√			X	Major barrier - Lift to be replaced with elevator; ramp railings do not meet standards. Fire alarm strobe lights required. To be completed through Capital Program, 2004.
<b>PARKDALE (S)</b>	√			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>PARLIAMENT (S)</b>	√			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007).
<b>PERTH/DUPONT (S)</b>	√			X	Major barrier - Lift to be replaced with elevator - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
<b>PLEASANT VIEW (N)</b>	√		√		

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
PORT UNION (E)	√			X	Major barrier - Entrance door to be replaced - To be completed through Capital Program (beyond 2007).
QUEEN/SAULTER (S)	√		√		
REXDALE (W)	√		√		
RICHVIEW (W)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
RIVERDALE (S)	√		√		
RUNNYMEDE (S)	√			X	Major barriers - Accessible ramp does not meet standards; automatic door required at main entrance; lift to be replaced with elevator. Fire alarm strobe lights required. To be completed through Capital Program, 2003.
S. WALTER STEWART (E)	√			X	Major barriers - Lifts to be replaced with elevator; accessible washroom, walkway and ramp do not meet standards. Fire alarm strobe lights required. To be completed through Capital Program, 2004.
SANDERSON (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
SERVICES BUILDING (N)	√		√		
SPADINA (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
ST. CLAIR/SILVERTHORN (S)		X		X	Major barriers - Library is not accessible; no accessible washroom; automatic door required - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
ST. LAWRENCE (S)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
STEELES (E)	√			X	Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
SWANSEA MEMORIAL (S)	√		√		

**BARRIER-FREE ACCESSIBILITY STATUS OF TPL BUILDINGS**

<b>Location (Region)</b>	<b>OBC Compliance</b>		<b>Compliance with City/Library Standards</b>		<b>Comments</b>
	<b>Yes</b>	<b>No</b>	<b>Yes</b>	<b>No</b>	
TAYLOR MEMORIAL (E)	√			X	Major barrier - Accessible washroom does not meet standards - To be completed through Capital Program (beyond 2007). Fire alarm strobe lights required - To be completed through Operating Budget, 2003.
THORNCLIFFE (E)	√		√		
TODMORDEN ROOM (E)	√		√		
TORONTO REFERENCE (S)	√			X	Fire alarm strobe lights; elevator audible floor call required - To be completed through Capital Program, 2003.
URBAN AFFAIRS (S)	√		√		
VICTORIA VILLAGE (N)	√			X	Major barrier - Ramp railing too wide - To be completed through Capital Program (beyond 2007).
WESTON (W)	√			X	Elevator telephone, Braille signage and audible floor call; parking signage, pavement markings and curb ramp hatch markings; accessible washroom sink and faucets required - To be completed through Operating Budget, 2003.
WOODSIDE SQUARE (E)	√		√		
WOODVIEW PARK (N)	√		√		
WYCHWOOD (S)	√			X	Fire alarm strobe lights; elevator telephone, Braille signage and audible floor call required - To be completed through Operating Budget, 2003. Barrier free access to mezzanine levels is not feasible.
YORK WOODS (N)	√		√		
YORKVILLE (S)	√		√		